


TECHNICAL BULLETIN

Issue Date: July 27, 2020

No. 09-416-20

ASTM E2140 Water Head Test 238T 16" 24 Ga.

McElroy Metal had its 238T 16" wide 24 gauge panel tested per ASTM E2140 on March 10, 2009. These test results may be applied to all widths of 238T panels both in 24 gauge and 22 gauge. The seam heights, panel clips, sealant type and sealant location are identical for these profiles.



TEST RESULTS

Time	Water Level	Observations
5 min	3"	No Leaks Observed
1 hr	6"	No Leaks Observed
3 hr	6"	No Leaks Observed
6 hr	6"	No Leaks Observed

Test Report No.: 09-0006T-13J

Dated: March 10, 2009

MANUFACTURING LOCATIONS

ADELANTO, CA	ASHBURN, GA	BOSSIER CITY, LA	CLINTON, IL	DIAMOND, MO	HOUSTON, TX	LEWISPORT, KY
MARSHALL, MI	MAUSTON, WI	MERKEL, TX	PEACHTREE CITY, GA	SUNNYVALE, TX	WINCHESTER, VA	