



TECHNICAL BULLETIN


Issue Date: April 2, 2015

No. 05-398-15

ASTM E1592 Wind Uplift Test

238T 24" 24 Ga.

McElroy Metal tested its 238T structural standing seam panel per ASTM E1592 between January 7, 2014 and January 24, 2014, using 24 Ga. MultiSpan Clips.



TEST RESULTS

Negative (uplift) loading				
Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.67 (AISI)
238T 24"	24	5'-0"	166.4	99.64

Test Report No. : 14-001

Dated: April 18, 2014

CORPORATE OFFICE
SHREVEPORT, LOUISIANA

BOSSIER CITY, LA
CLINTON, IL

PEACHTREE CITY, GA
MARSHALL, MI

WINCHESTER, VA
ADELANTO, CA

LEWISPORT, KY
MAUSTON, WI

ASHBURN, GA
MERKEL, TX

SUNNYWALE, TX
HOUSTON, TX