

# TECHNICAL BULLETIN


Issue Date: March 5, 2015

No. 05-397-15

## ASTM E1592 Wind Uplift Test

### Medallion I 12" 24 Ga.

McElroy Metal tested its Medallion I standing seam panel per ASTM E1592 between July 25, 2007 and August 24, 2007.



### TEST RESULTS

Negative (uplift) loading				
Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 2.0 (AISI)
Medallion I 12"	24	1'-0"	124.8	62.4
Medallion I 12"	24	2'-0"	78.0	39.0
Medallion I 12"	24	3'-0"	52.0	26.0

Test Report No. : 14-003

Dated: August 20, 2014

**CORPORATE OFFICE**  
**SHREVEPORT, LOUISIANA**

BOSSIER CITY, LA  
CLINTON, IL

PEACHTREE CITY, GA  
MARSHALL, MI

WINCHESTER, VA  
ADELANTO, CA

LEWISPORT, KY  
MAUSTON, WI

ASHBURN, GA  
MERKEL, TX

SUNNYWALE, TX  
HOUSTON, TX