

# TECHNICAL BULLETIN


Issue Date: December 21, 2023

No. 09-417-23

## ASTM E2140 Water Head Test

### Trap Tee 24” 24 Ga.

McElroy Metal had its Trap Tee 24” wide 24 gauge panel tested per ASTM E2140 on December 5, 2023. These test results may be applied to all widths of Trap Tee panels both in 24 gauge and 22 gauge. The seam heights, panel clips, sealant type and sealant location are identical for these profiles.



### TEST RESULTS

Time	Water Level	Observations
5 min	3"	No Leaks Observed
1 hr	6"	No Leaks Observed
3 hr	6"	No Leaks Observed
6 hr	6"	No Leaks Observed

Test Report No.: 90-0112T-23

Dated: December 5, 2023

#### MANUFACTURING LOCATIONS

ADELANTO, CA    ASHBURN, GA    BOSSIER CITY, LA    CLINTON, IL    DIAMOND, MO    HOUSTON, TX    LEWISPORT, KY  
 LOCKHART, TX    MARSHALL, MI    MAUSTON, WI    MERKEL, TX    PEACHTREE CITY, GA    SUNNYVALE, TX    WINCHESTER, VA